OCFD 101-90

OSSIPEE CORNER FIRE DEPARTMENT
WOODSTOVE INSPECTION

NO.

NAME _____ DATE _____ PHONE # _____

ADDRESS _____ INSURANCE CO. _____

	Yes	No
Is the stove listed by a recognized State of NH independent testing lab?	☐	☐
Is the stove at least 36" from an unprotected wall or installed in accordance with the manufacturers requirements?*	☐	☐
Is the stove at least 18" from any masonry wall?	☐	☐
Is there a hearth or shield to protect the floor?	☐	☐
Does the hearth or shield extend at least 18" beyond the sides of the stove?	☐	☐
If the stove loads from the front, does the hearth or shield extend 18" in front of the stove?	☐	☐
Is the stove arranged so that there is at least 36" clearance from any combustibles or satisfy the requirements of the manufacturer?*	☐	☐
Is the stove stable and free from cracks?	☐	☐
Does the stove have one of the following:		
A. Bottom lined with at least 2" of sand.	☐	☐
B. Bottom lined with fire brick.	☐	☐
C. A grate on which the wood is burned.	☐	☐
Is the flue pipe in satisfactory condition? — Free from cracks, rust, holes and damage	☐	☐
Is the flue pipe secured with at least three sheet metal screws at each joint?	☐	☐
Is the damper installed in the flue pipe?	☐	☐
Is the chimney in satisfactory condition?	☐	☐
If the chimney is of masonry construction, is it flue lined?	☐	☐
Is the chimney satisfactorily free from creosote buildup?	☐	☐
Is there a cleanout door on the chimney?	☐	☐
Is there a properly installed smoke detector on the premises?	☐	☐
Is the stove pipe at least 18" from combustible wall with protection.*	☐	☐
The following are Fire Department recommendations:		
A. Are emergency numbers placed near the phones?	☐	☐
B. Is there a fire extinguisher on the premises?	☐	☐
C. Is there a metal can provided for the disposal of ashes?	☐	☐

*Clearance reduction shall be in accordance with NFPA 211-34

COMMENTS:

Stove installation is Approved Disapproved (in accordance with OCFD and NFPA recommendations)

_____ _____

Owner/Occupant Signature Inspector

DISCLAIMER: This inspection is conducted for the benefit of the homeowner. This department will be free of any liability by reason of damage caused by condition which may or may not have been found to be in compliance with the above guidelines.

Blacksmith Printing